

Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223

C

Ε

Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/13/2016 Received: 08/31/2016 Sampled By: Rebecca Wale Work Order: 6244011

Project:

Project #:

Sample Type :

Sampling Location: Linfield College

Linfield College

Attn: Rebecca Wale 900 SE Baker St

McMinnville OR, 97128 T Phone: (503) 883-2431

Lab Number	· · · · · · · · · · · · · · · · · · ·					
	Code Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6244011-01	Sample Name: WHIT-I-S-17 I Sampled: 8/23/16 14:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-02	Sample Name: WHIT-I-S-15 I Sampled: 8/23/16 14:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-03	Sample Name: WHIT-I-S-22 I Sampled: 8/23/16 14:00					Matrix: Drinking Water
+ <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-04	Sample Name: CAM-O-S-kit I Sampled: 8/23/16 14:00					Matrix: Drinking Water
+ <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-05	Sample Name: CAM-O-DF-RRN Sampled: 8/23/16 14:00					Matrix: Drinking Water
+ <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-06	Sample Name: CAM-I-S-113 N Sampled: 8/23/16 14:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-07	Sample Name: CAM-1-DF-113 N Sampled: 8/21/16 14:05					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-08	Sample Name: CAM-2-DF-209 N Sampled: 8/21/16 14:15					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-09	Sample Name: CAM-3-DF-301 N Sampled: 8/21/16 14:20					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-10	Sample Name: POTA-0-S-014 N Sampled: 8/24/16 9:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	2.1	ppb	2.0	20 ppb	10/12/16 16:12



Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223

C

Ε

N

Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/13/2016 Received: 08/31/2016 Sampled By: Rebecca Wale Work Order: 6244011

Project:

Project #:

Sample Type:

Sampling Location: Linfield College

Linfield College

Attn: Rebecca Wale 900 SE Baker St

McMinnville OR, 97128 Phone: (503) 883-2431

Lab Number						
	Code Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6244011-11	Sample Name: POTA-0-S-Class I Sampled: 8/24/16 9:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	4.1	ppb	2.0	20 ppb	10/12/16 16:12
6244011-12	Sample Name: POTA-1-S-112 I Sampled: 8/24/16 9:00	į.				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-13	Sample Name: POTA-2-S-222 I Sampled: 8/24/16 9:00	Market and the second				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	28.8	ppb	2.0	20 ppb	10/12/16 16:12 MCLE
6244011-14	Sample Name: POTA-3-S-335 I Sampled: 8/24/16 9:00					Matrix: Drinking Water
+ <i>Lead</i>	1030 EPA 200.9	23.7	ppb	2.0	20 ppb	10/12/16 16:12 MCLE
6244011-15	Sample Name: 1142-I-S-Hall I Sampled: 8/30/16 11:00					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-16	Sample Name: TJD-2-S-216 I Sampled: 8/30/16 11:15	e e				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-17	Sample Name: TJD-3-S-321 I Sampled: 8/30/16 11:17	en de la companya de				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-18	Sample Name: TJD-1-DF-104 N Sampled: 8/30/16 13:30					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-19	Sample Name: TJD-1-DF- ADA 104 Sampled: 8/30/16 13:30	N				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-20	Sample Name: TJD-2-DF-22 N Sampled: 8/30/16 13:35	1574 in 1981 a				Matrix: Drinking Water
+ <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12



Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223

Ε

Ν

Tel.: (503) 639-9311 Fax: (503) 684-1588

Linfield College

900 SE Baker St

Attn: Rebecca Wale

McMinnville OR, 97128

Phone: (503) 883-2431

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 10/13/2016 Received: 08/31/2016 Sampled By: Rebecca Wale Work Order: 6244011

Project:

Project #:

Sample Type:

Sampling Location: Linfield College

Lab Number						
	Code Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6244011-21	Sample Name: TJD-2-DF-ADA-222 Sampled: 8/30/16 13:35	N				Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-22	Sample Name: DAN-1-S-3I- New F Sampled: 8/30/16 13:40					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	22.1	ppb	2.0	20 ppb	10/12/16 16:12 MCLE
6244011-23	Sample Name: DAN-1-S-3I- Filter Sampled: 8/30/16 13:40					Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	ND	ppb	2.0	20 ppb	10/12/16 16:12
6244011-24	Sample Name: DAN-2-23 I- New F Sampled: 8/30/16 13:42				,	Matrix: Drinking Water
† <i>Lead</i>	1030 EPA 200.9	8.5	ppb	2.0	20 ppb	10/12/16 16:12
6244011-25	Sample Name: DAN-2-23 I- Filter Sampled: 8/30/16 13:42					Matrix: Drinking Water

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

EPA 200.9

1030

MCL = Maximum Contamination Limit

2.0

20 ppb

10/12/16 16:12

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

ppb

ND

Approved by:

+Lead

driana Gonzalez-Gray Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.