



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/26/2016
Sampled By:
Work Order: 6270003

C
L
I
E
N
T

Linfield College
Attn: Rebecca Wale
900 SE Baker St
McMinnville OR, 97128
Phone: (503) 883-2431

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6270003-01	Sample Name: POTA-0-010-SIL-filtered Sampled: 9/21/16 12:01		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-02	Sample Name: POTA-0-010-SIC-filtered Sampled: 9/21/16 12:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-03	Sample Name: POTA-0-010 ISR Sampled: 9/21/16 12:01		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-04	Sample Name: POTA-0-010-SLI Sampled: 9/21/16 12:02		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-05	Sample Name: POTA-0-010-SIC Sampled: 9/21/16 12:03		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-06	Sample Name: JAN-2-S-203I Sampled: 9/2/16 14:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-07	Sample Name: JAN-2-S-204I Sampled: 9/2/16 14:03		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-08	Sample Name: JAN-2-S-209I Sampled: 9/2/16 13:58		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-09	Sample Name: JAN-2-S210I Sampled: 9/2/16 14:06		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-10	Sample Name: JAN-2-S-213I Sampled: 9/2/16 13:48		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/26/2016
Sampled By:
Work Order: 6270003

C Linfield College
L Attn: Rebecca Wale
I 900 SE Baker St
E McMinnville OR, 97128
N Phone: (503) 883-2431
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6270003-11	Sample Name: JAN-2-S-214I Sampled: 9/2/16 13:50		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-12	Sample Name: JAN-2-S-215I Sampled: 9/2/16 13:53		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-13	Sample Name: JAN-2-S-216I Sampled: 9/2/16 13:55		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-14	Sample Name: JAN-2-S-218I Sampled: 9/2/16 13:54		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-15	Sample Name: JAN-2-S-220I Sampled: 9/2/16 13:50		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-16	Sample Name: JAN-2-S-208I Sampled: 9/2/16 14:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-17	Sample Name: JAN-2-S-205I Sampled: 9/2/16 14:03		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-18	Sample Name: JAN-2-S-206I Sampled: 9/2/16 14:05		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-19	Sample Name: JAN-3-S-BRI Sampled: 9/2/16 14:11		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-20	Sample Name: GRO-1-S-101I Sampled: 9/2/16 14:19		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/26/2016
Sampled By:
Work Order: 6270003

C Linfield College
L Attn: Rebecca Wale
I 900 SE Baker St
E McMinnville OR, 97128
N Phone: (503) 883-2431
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6270003-21	Sample Name: GRO-1-S-102I Sampled: 9/2/16 14:19		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-22	Sample Name: MIC-1-S-RRI Sampled: 9/2/16 12:55		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-23	Sample Name: MIC-2-S-RRI Sampled: 9/2/16 12:57		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-24	Sample Name: JAN-1-S-RRI Sampled: 9/2/16 13:07		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-25	Sample Name: JAN-1-S-101I Sampled: 9/2/16 13:10		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-26	Sample Name: JAN-1-S-102I Sampled: 9/2/16 13:13		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-27	Sample Name: JAN-1-S-104I Sampled: 9/2/16 13:14		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-28	Sample Name: JAN-1-S-107I Sampled: 9/2/16 13:16		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-29	Sample Name: JAN-1-S-105I Sampled: 9/2/16 13:17		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6270003-30	Sample Name: JAN-1-S-106I Sampled: 9/2/16 13:19		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/26/2016
Sampled By:
Work Order: 6270003

C **Linfield College**
L Attn: Rebecca Wale
I 900 SE Baker St
E McMinnville OR, 97128
N Phone: (503) 883-2431
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6270003-31	Sample Name: JAN-1-S-108I Sampled: 9/2/16 13:20		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-32	Sample Name: FRE-1-S-104I Sampled: 9/16/16 10:32		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	63.7	ppb	4.0	20 ppb	10/31/16 16:47 MCLE
6270003-33	Sample Name: FRE-1-S-104RRI Sampled: 9/16/16 10:31		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-34	Sample Name: AND-1-S-106I Sampled: 9/16/16 10:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-35	Sample Name: WHI-1-S-112I Sampled: 9/16/16 11:01		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-36	Sample Name: PIO-3-S-307RRI Sampled: 9/16/16 14:39		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-37	Sample Name: LAR-1-S-119I Sampled: 9/16/16 11:30		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-38	Sample Name: MIL-1-S-102RRI Sampled: 9/16/16 11:35		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-39	Sample Name: MIL-2-S-202RRI Sampled: 9/16/16 11:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-40	Sample Name: MIL-2-S-222RRI Sampled: 9/16/16 11:41		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/26/2016
Sampled By:
Work Order: 6270003

C Linfield College
L Attn: Rebecca Wale
I 900 SE Baker St
E McMinnville OR, 97128
N Phone: (503) 883-2431
T

Project:
Project # : -
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6270003-41	Sample Name: GRO-1-S-103I Sampled: 9/2/16 14:22		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-42	Sample Name: GRO-2-S-209I Sampled: 9/2/16 14:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-43	Sample Name: GRO-2-S-203I Sampled: 9/2/16 14:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-44	Sample Name: GRO-2-S-204I Sampled: 9/2/16 14:26		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-45	Sample Name: GRO-2-S-201I Sampled: 9/2/16 14:25		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-46	Sample Name: GRO-2-S-211I Sampled: 9/2/16 14:30		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47
6270003-47	Sample Name: GRO-2-S-208I Sampled: 9/2/16 14:32		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/31/16 16:47

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director